



March 22, 2016

LUBRIZOL  
JOHN PRITCHARD  
9911 BRECKSVILLE ROAD  
BRECKSVILLE OH 44141

Re: Description: PIPES AND FITTINGS, CPVC  
Manufacturer: LUBRIZOL  
Product Name: (trans id 2675613) CORZAN HP  
Model Number(s): SCH 80 IPS CPVC PIPE AND FITTINGS UP TO 4"  
Product File No: 20160064

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 384.30 (4) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of March 2021.

This approval supersedes the approval issued on May 18, 2011 under product file number 20110054.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product is approved through the testing and certification of NSF SE 8459. This Special Engineered Specification (SE) tests Schedule 40 and 80 pipe and fittings high hydrostatic design basis (HDB) at 180° F.

An NSF SE Specification is similar to a consensus standard, such as an ASTM standard in that it defines the physical properties and performance characteristics of a product. SE Specifications are developed by NSF international and other interested parties to evaluate new and innovative products when on consensus standard exists.

- This product meets or exceeds the adopted standards of the Wisconsin Uniform Plumbing Code. Also meets the required temperature and pressure requirements in SPS 384.30 (4) (e).
- This product shall only be used with fittings made, of the same material, by Harvel, Nibco or Ipex.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter  
Environmental Engineer - Plumbing Product Reviewer  
Department of Safety and Professional Services  
Division of Industry Services  
Bureau of Technical Services  
(608) 267-1401 Phone  
(608) 267-9723 Fax  
glen.schlueter@wi.gov E-mail